

# **TAMILNADU FIRE AND RESCUE SERVICE**

## **SCHOOL NO OBJECTION CERTIFICATE**

**R.C.NO: 220/V/2021**

**DATED: 28/06/2021**

Certificated that the **M/S. SWAMI VIVEKANANDA VIDYA PEEDAM**, at Survey No. 1087/1, 1088, 1089/1, 1093, 1094, 1097/1, 1097/3, 1097/4, 1097/5, 1098/6, 1098/8, 1098/9, 1103/1, 1103/2, 1103/3, 1103/4A, 1103/4B, 1103/5, Sri Ramakrishnapuram, Chellaperumal Nagar, Sriperumbudur Town & Taluk, Kancheepuram Dist. comprised of 1 Ground Floor and 2 (upper floors) occupied by **SWAMI VIVEKANANDA VIDYA PEEDAM** (name of the Institution) have Fire Service Rules, and verified by the officers concerned of Fire Service on 11/06/2021 (date of inspection) in the presence of PRINCIPAL, **SWAMI VIVEKANANDA VIDYA PEEDAM**, Survey No. 1087/1, 1088, 1089/1, 1093, 1094, 1097/1, 1097/3, 1097/4, 1097/5, 1098/6, 1098/8, 1098/9, 1103/1, 1103/2, 1103/3, 1103/4A, 1103/4B, 1103/5, Sri Ramakrishnapuram, Chellaperumal Nagar, Sriperumbudur Town (name and address of the Manager/Secretary or his representative) and that the building/premises is for occupancy class School Premises With effect from 28/06/2021 for a period of 27/06/2022 Years in accordance with rule and subject to compliance of the conditions.

## **CONDITIONS**

1. This License is valid for One year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
6.
  - a) Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2016.
  - b) The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.
  - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the Classrooms have only One entrance, the capacity of the class room shall have to be limited to 45 students.
7. Hose Reel System should be Provide within One Year in all floors.

TO:

**M/S. SWAMI VIVEKANANDA VIDYA PEEDAM,  
Sri Ramakrishnapuram,  
Chellaperumal Nagar,  
Sriperumbudur Town & Taluk,  
Kancheepuram Dist.**

Copy to district officer

  
**Station Officer,  
Fire-Rescue Service  
Sriperumbudur-602 105**